

**THIS PERMIT EXPIRES IN 90 DAYS.
COMPLETED PERMIT MUST BE SIGNED
BEFORE LATERALS ARE BURIED**

**VILLAGE OF PLOVER
WATER/WASTEWATER CONNECTION PERMIT**

\$40.00 FEE

KEY # _____ Date _____

Name _____ RESIDENTIAL:

Site Address _____ COMMERCIAL:

Phone: _____ INDUSTRIAL:

In consideration of the granting of this permit, the applicant agrees:

1. To accept and abide by all the provisions of applicable Utility Ordinances
2. To maintain the water line from the building to the lot line, including the curb stop and valve box, at owners expense
3. To maintain the wastewater lateral from the building to the main, at owners expense
4. To notify the Building Inspector when the installation is made
5. To assure the Village compliance with the Wisconsin Plumbing Code
6. **Zero Lot Line buildings require separate water lines**
7. That they will have a meter installed before using any Village of Plover water. (The Village of Plover has an ordinance providing a \$1,000 fine to anyone using Village of Plover water without it being properly metered).
8. The Village will not be responsible for frozen pipes.

(Signature of Applicant)

This is to certify that a water and/or wastewater hook-up was made on the above described property in accordance with Village Ordinances and the Wisconsin Plumbing Code. It is understood that the Village recommends insulating pipes in snow plowed areas to prevent frozen pipes.

Lateral(s) were properly installed on: _____
(Date)

Name of Contractor: _____

License Number: _____

Address: _____

Signature: _____

VILLAGE OF PLOVER
LATERAL INSPECTION REPORT

Date & Time:

Excavator: Plumber:

Village Inspector: Mike John

Sewer Lateral: Trench not entered; too steep/unsafe Tracer wire provided along non-conductive lines
Minimum #14 Solid Copper

Size:
Length:

Material:
Depth at lot line:

- Pressure tested air water
Frost sleeve on clean out pipe
Fernco, banded and tight
Glue joints, glued and tight
Minimum 3'6" depth in snow covered areas
Minimum 18" depth for pipe to grease interceptor
Insulation provided at storm sewer crossing
Grease trap interior exterior size

- Trench under pipe compacted
Slope on pipe, 1/8" per foot minimum
Clean-outs. Minimum 75 foot interval if lateral is longer than 100 feet to main
Minimum 6'0" depth in snow plowed areas
<6' depth in snow plowed areas requires 2" foam board (R10) 4' wide @ 6" above pipe

Water Service: Trench not entered: too steep/unsafe Tracer wire provided along non-conductive lines
Minimum #14 Solid Copper

ZERO LOT LINE RESIDENTIAL REQUIRES SEPARATE WATER LINES!

Size:
Length:

Material:
Depth at lot line:

- Connections tight. Lock screw tight
Only brass fittings, couplers or reducers
Curb stop riser threaded on tight
Pressure tested air water
Waterline 2" or less shall be minimum 30" from or 12" above sewer line except within 5' of bldg
Water lines shall be 12" above or 18" below sewer within 10' of point of crossing

- Required 2" foam board (R10) [4' wide] when <6'6" depth
Curb stop riser not bent and set to straight vertical position
Recommended 2" foam board (R10) [4' wide] in snow plowed areas with any depth provided not provided
Water lines 2.5" &> shall be 8' horizontally from sewer lines
Insert provided on end of plastic water line
Insulation provided at storm sewer crossing